



USER'S MANUAL

chroma+scan 24x0
Version 5.4.4.2

Proprietary

This document, submitted in confidence, contains proprietary information which shall not be reproduced or transferred to other documents or disclosed to others or used for manufacturing or any other purpose without prior written permission of LMI Technologies Inc.

No part of this publication may be copied, photocopied, reproduced, transmitted, transcribed, or reduced to any electronic medium or machine readable form without prior written consent of LMI Technologies, Inc.

Trademarks and Restrictions

DynaVision®, chroma+scan®, Selcom®, FireSync®, and Sensors That See® are registered trademarks of LMI Technologies, Inc. Any other company or product names mentioned herein may be trademarks of their respective owners. Information in this manual is subject to change.

This product is designated for use solely as a component and as such it does not comply with the standards relating to laser products specified in U.S. FDA CFR Title 21 Part 1040.

LMI Technologies, Inc.
1673 Cliveden Ave.
Delta, BC V3M 6V5

Telephone: +1 604 636 1011
Facsimile: +1 604 516 8368
www.lmi3D.com

Table of Contents

1	Laser Safety	5
1.1	General Information	5
1.2	Laser Classification	6
1.2.1	Laser Classes	6
1.2.2	User Precautions & OEM Responsibilities	7
1.2.3	Class 3B/IIIb OEM Responsibilities	7
1.3	Requirements for Laser Systems Sold or Used In the USA	9
1.4	chroma+scan 24x0 Laser Safety Specification	9
2	Proper Handling and Precautions	10
2.1	System Installation	10
2.1.1	Component Grounding	10
2.1.2	Shielded Cable	10
2.1.3	Power Supply	10
2.1.4	Uninterruptible Power Supply (UPS)	11
2.1.5	Installation Environment	11
2.2	Temperature and Humidity	11
2.3	Maintenance	11
2.4	Laser Lifetime	11
3	Product Overview	12
3.1	Introduction	12
3.2	Measurement Principles	12
3.3	Sensor Models	13
3.4	Features	14
4	System	15
4.1	List of Components	15
4.1.1	FireSync Master	15
4.1.2	Station Computer	15
4.1.3	Client Computer	16
4.1.4	Network Switch	16
4.1.5	Power Supply	16
4.1.6	FireSync Network Cordsets	16
4.1.7	Other Cabling	17
4.1.8	System Calibration Target	18
4.1.9	Sensors	18
4.2	Connections	19
4.2.1	Power to Master 1200/2400	19
4.2.2	Master 1200/2400 to Sensors	19
4.2.3	Safety Interlock on Master 1200/2400	20
4.2.4	Sensors, Master 1200/2400 and Station to Gigabit Switch	20
4.2.5	Client computer	20
5	Specifications	21
5.1	Models	21
5.2	Performance	21
5.3	Environment	21
5.4	Coordinate Definitions	22
5.5	Cleaning	22
5.6	Master 2400	22

5.6.1	Mechanical Information	22
5.6.2	Electrical Information.....	23
5.6.3	LED Indicators	23
5.6.4	Terminal plugs	24
5.7	Cordsets	26
5.7.1	Network Cordset	26
5.7.2	Ethernet Cable	26
5.8	Dimensions & Mounting	27
5.8.1	chroma+scan 2420	27
5.8.2	chroma+scan 2440	29
5.8.3	chroma+scan 2460	31
5.8.4	Master 2400	33
6	Software.....	34
6.1	Components.....	34
6.2	Operation Modes.....	34
6.3	FireSync Client.....	35
6.3.1	Installation.....	35
6.3.2	Connection.....	35
6.3.3	Navigation	36
6.3.4	Video Mode.....	39
6.3.5	Free Mode	40
6.3.6	Calibration Mode	41
6.4	Software Interface	43
6.4.1	The FireSync Host Protocol	43
6.4.2	Zen Api and example source code	43
6.4.3	System Settings	44
6.4.4	Video Mode Result Format.....	47
6.4.5	Free Mode Result Format	48
6.4.6	Calibration Mode Result Format.....	49
7	Warranty	50
7.1	Warranty policies.....	50
7.2	Return policy	50
8	Getting Help	51

1 Laser Safety


1.1 General Information

The laser light sources used in LMI Sensors are semiconductor lasers emitting visible light.

LMI Laser Sensors have a 2/II, 3R/IIIa or 3B/IIIb classification depending on model.

Class 2/II and 3R/IIIa sensors are referred to as “products” indicating that they fully comply with the standards relating to laser products specified in IEC 60825-1 and U.S. FDA CFR Title 21 Part 1040 except for deviations pursuant to Laser Notice No. 50, dated July 26, 2001.

Class 3B/IIIb sensors are sold only to qualified OEM’s as “components” for incorporation into their own equipment. The sensors do not incorporate safety items which the OEM is required to provide in their own equipment (e.g. remote interlocks, key control). As such these sensors do not fully comply with the standards relating to laser products specified in IEC 60825-1 and FDA CFR Title 21 Part 1040.



Caution! Use of controls or adjustments or performance of procedures other than those specified herein may result in hazardous radiation exposure.

1. **International Standard IEC 60825-1 (2001-08) Consolidated edition**, Safety of laser products – Part 1: Equipment classification, requirements and user's guide
2. **Technical Report TR 60825-10**, safety of laser products – Part 10. Application guidelines and explanatory notes to IEC 60825-1
3. **Laser Notice No. 50**, FDA and CDRH <http://www.fda.gov/cdrh/rad-health.html>


1.2 Laser Classification

1.2.1 Laser Classes

Class 2/II laser products:

Class 2/II laser products would not cause permanent damage to the eye under reasonably foreseeable conditions of operation, provided that any exposure can be terminated by the blink reflex (assumed to take 0.25 sec). Because classification assumes the blink reflex, the wavelength of light must be in the visible range (400 nm to 700 nm). The Maximum Permissible Exposure (MPE) for visible radiation for 0.25 second is 25 Watt per square meter, which is equivalent to 1 mW entering an aperture of 7 mm diameter (the assumed size of the pupil).

Labels reprinted here are examples relevant to the laser classes. For detailed specifications observe the label on your laser sensor




Class 3R/IIIa laser products:

Class 3R/IIIa laser products emit radiation where direct intrabeam viewing is potentially hazardous, but the risk is lower than for 3B/IIIb lasers. Fewer manufacturing requirements and control measures for users apply than for 3B/IIIb lasers.



Class 3B/IIIb laser components:

Class 3B/IIIb components are unsafe for eye exposure. Usually only ocular protection would be required. Diffuse reflections are safe if viewed for less than 10 seconds.



1.2.2 User Precautions & OEM Responsibilities

The specific user precautions as specified in IEC 60825-1 and FDA CFR Title 21 Part 1040 are:

Requirements	Class 2/II	Class 3R/3a	Class 3B/3b
Remote interlock	Not required	Not required	Required**
Key control	Not required	Not required	Required** Cannot remove key when in use
Power-On delays	Not required	Not required	Required**
Beam attenuator	Not required	Not required	Required**
Emission indicator	Not required	Not required	Required**
Warning signs	Not required	Not required	Required**
Beam path	Not required	Terminate beam at useful length	Terminate beam at useful length
Specular reflection	Not required	Prevent unintentional reflections	Prevent unintentional reflections
Eye protection	Not required	Not required	Required under special conditions
Laser safety officer	Not required	Not required	Required
Training	Not required	Required for operator and maintenance personnel	Required for operator and maintenance personnel

LMI Class 3B/IIIb laser components do not incorporate the safety items indicated by asterisks ** in the table above. These items must be added and completed by the OEM in the system design.

1.2.3 Class 3B/IIIb OEM Responsibilities

LMI Technologies has filed reports with the FDA to assist the OEM in achieving certification of their laser products. The OEM can reference these reports by an accession number that will be provided upon request.

Detailed descriptions of the safety items that must be added to the OEM design are listed below:

Remote Interlock

A remote interlock connection must be present in Class IIIB laser systems. This permits remote switches to be attached in serial with the keylock switch on the controls. The deactivation of any remote switches must prevent power from being supplied to any lasers.

Key Control

A key operated master control to the lasers that prevents any power from being supplied to the lasers while in the OFF position. The key can be removable in the OFF position but the switch must not allow the key to be removed from the lock while in the ON position.

Power-On Delays

A delay circuit is required that illuminates warning indicators for a short period of time prior to supplying power to the lasers.

Beam Attenuators

A permanently attached method of preventing human access to the laser radiation other than switches, power connectors or key control must be employed. On some LMI laser sensors, the beam attenuator is supplied with the sensor as an integrated mechanical shutter.

Emission Indicator

It is required that the controls that operate the sensors incorporate a visible or audible indicator when power is applied and the lasers are operating. If distance (>2 m between sensor and controls) or mounting of sensors intervenes with observation of these indicators, a second power-on indicator should be mounted at some readily observable position. When mounting the warning indicators, it is important not to mount them in a location that would require human exposure to the laser emissions.

Warning Signs

Laser warning signs must be located in the vicinity of the sensor such that they will be readily observed. Examples of laser warning signs are:



FDA Example



IEC Example

1.3 Requirements for Laser Systems Sold or Used In the USA

The OEM's laser system which incorporates laser components or laser products manufactured by LMI Technologies requires certification by the FDA.

It is the responsibility of the OEM to achieve and maintain this certification.

OEM's are advised to obtain the information booklet *Regulations for the Administration and Enforcement of the Radiation Control for Health and Safety Act of 1968*: HHS Publication FDA 88-8035.

This publication, containing the full details of laser safety requirements, can be obtained directly from the FDA, or downloaded from their website at <http://www.fda.gov/cdrh>.

1.4 chroma+scan 24x0 Laser Safety Specification

Laser Classification: 3B/IIIb laser component

Peak Power: 130mW

Emitted Wavelength: 660nm

2 Proper Handling and Precautions

2.1 System Installation

2.1.1 Component Grounding

All sensors should be grounded to the earth/chassis through their housing. For sensors with through-hole mounts, this can be accomplished by using star washers on the mounting bolts. The star washers must cut through the powder coating to provide electrical conductivity from the mounting hardware to the sensor housing. For sensors with tapped hole mounts, conductive hardware must be used between the sensor and the frame. This must be checked with a multi-meter by ensuring electrical continuity between the frame and the connector housing on the sensor. It is imperative that the scan frame or chassis that the sensor is mounted to is connected to earth ground.

Master networking products should have the housing connected to earth ground. This can be accomplished using star washers on the mounting holes or through the earth ground connection located on the rear of the Master 1200 and 2400. FireSync Networking products should be installed inside electrical cabinets that are suitably grounded to earth ground.

2.1.2 Shielded Cable

LMI Technologies recommends the use of shielded cables in all environments to ensure isolation from electrical noise. The shield should be electrically connected to both the sensor housing through the connector housing and to the electrical box containing the Master.

LMI Technologies supplies both shielded FireSync cordsets and shielded FireSync cable for building cordset.

2.1.3 Power Supply

The user must provide a suitable +48VDC power supply for the system capable of handling an infinite capacitive load. These power supplies must be isolated such that DC ground is NOT tied to AC ground. The power supply should be of a suitable capacity for the size of the system.

LMI Technologies recommends the Phoenix Contact QUINT series of power supplies.

2.1.4 Uninterruptible Power Supply (UPS)

To maximize the life of the sensor, LMI Technologies recommends the use of an on-line double-conversion UPS whenever the quality of the electrical supply to the system is poor. This includes but is not limited to when the electrical supply:

- contains high frequency noise (due to other electronics, electric motors or other factors)
- is prone to “brown-out” conditions or large voltage fluctuations
- is prone to electrical surges or spikes due other components or electrical storms.

LMI Technologies recommends the Tripp Lite SU2200RTXL2UA UPS.

2.1.5 Installation Environment

To prevent damage to LMI 3D sensors and ensure reliable operation, avoid installing the sensor in locations:

- that are humid, dusty, or poorly ventilated
- with a high temperature such as a place exposed to direct sunlight
- where there are flammable or corrosive gases
- where the unit may be directly subjected to vibration or impact
- water, oil, or chemicals may splash onto the unit
- where static electricity is easily generated

2.2 Temperature and Humidity

LMI 3D Sensors are rated for operation between 0- 50°C, and 25-85% Relative Humidity (non-condensing).

2.3 Maintenance

LMI 3D sensors are high-precision optical instruments. To ensure the highest accuracy is achieved in all measurements, the windows on the front of the sensor should be kept clean and clear of debris.

Use dry, clean air to remove dust or other dirt particles. If dirt remains, clean the windows carefully with a soft, lint-free cloth using an ammonia based cleaner. Ensure that no residue is left on the windows after cleaning.

2.4 Laser Lifetime

LMI Technologies uses semiconductor lasers in their 3D measurement sensors. To maximize the lifespan of the sensor it is recommended to turn off the laser by stopping the sensor whenever it is not in use.


3 Product Overview

3.1 Introduction

The chroma+scan 24x0 is the new-generation, high-speed, high-density 3D profile scanning system for primary log optimization. The sensors are based on LMI's field-proven FireSync platform, which provides a synchronized, scalable, distributed vision processing architecture for building reliable, high performance systems. High reliability and simple, rapid installation are achieved with a single cable for power, data, and synchronization. Communication is via Gigabit Ethernet.


3.2 Measurement Principles

The chroma+scan 24x0 sensors function on the principle of structured light triangulation. A semiconductor laser with special optics projects fans of light onto the target. Digital cameras mounted at an angle to the laser plane acquire images of the light pattern created on the target. These images contain the basic information needed to compute distances to the target.



3.3 Sensor Models


Three models exist in the chroma+scan 24x0 family: the chroma+scan 2420, 2440 and 2460.



chroma+scan 2420



chroma+scan 2440



chroma+scan 2460

3.4 Features

The chroma+scan 2460 provides the densest profile spacing in a cost-effective 4' sensor footprint, whereas the chroma+scan 2440 provides the same 6" profile spacing, but in a flexible 2' sensor footprint. The chroma+scan 2420 is an economical choice, providing 12" profile spacing in the 4' sensor footprint.

4 System


4.1 List of Components

A chroma+scan 24x0 system consists of following components:

- FireSync Master 400/800/1200/2400
- Station computer (Host computer)
- Client computer
- Network switch
- 48V Power Supply
- FireSync Network Cordsets
- Other cabling: Ethernet, Power & Encoder
- Scanner Frame
- System Calibration Target
- chroma+scan 24x0 sensor(s)

4.1.1 FireSync Master

The FireSync Master provides sensor power, safety interlock and broadcasts system-wide synchronization information (ie. time, encoder count, and digital I/O states) to all sensors. LMI Technologies provides a Master 400, 800, 1200, or 2400.



Master 2400

Warning! Use extreme caution wiring the FireSync master. Do not plug Ethernet equipment into the RJ45 ports.

4.1.2 Station Computer

A chroma+scan 24x0 system needs a Station computer in order to operate. This computer is not provided by LMI Technologies.

The station must have two Ethernet adapters. One Gigabit Ethernet adapter is connected to the sensors network via a gigabit Ethernet network switch. This adapter on must be assigned a static IP in the range 90.0.0.1 to 90.0.0.5. We refer to this as the “IN”

adapter. The second Gigabit Ethernet adapter must also be assigned a static IP of the user's preference. This is the "OUT" adapter.

After installing the chroma+scan 24x0 Station software this computer acts as a FireSync Host Protocol Server. "OUT" is to be used for the Host Protocol. The next step is to upgrade the Station and sensors by sending an upgrade package over the FireSync Host Protocol with a Client computer.

For more information about the FireSync Host Protocol, please refer to the in the *Host Protocol Reference Manual*. Refer to the *Station Setup Guide* for complete details on the FireSync Station.

4.1.3 Client Computer

The Client computer connects to the Station using the FireSync Host Protocol. This computer is not provided by LMI Technologies.

The Client computer must be equipped with a Gigabit Ethernet adaptor to communicate with the Station. The FireSync Host Protocol allows any OS for communication with the Station. However, the Client installer provided by LMI Technologies requires Windows XP or Windows 7.

4.1.4 Network Switch

The Network Switch connects all the sensors in the system to the Station and the Master. This switch must be Gigabit rated and have enough GigE ports to connect to each sensor plus two extra ports to connect to the Station and the Master.

A network switch is required in a chroma+scan 24x0 sensor system. This switch is not provided by LMI Technologies.

4.1.5 Power Supply

The user must provide a suitable +48VDC power supply for the system.

These power supplies must be isolated! This means that DC ground is NOT tied to AC ground!

LMI Technologies recommends use of a Phoenix Contact, QUINT, 10 Amp power supply (for +48VDC). This is a DIN rail mounted device that can be connected in parallel to increase the overall available power.

Voltage	+48VDC
Model	QUINT-PS-100-240AC/48DC/10
Order number	2938248

4.1.6 FireSync Network Cordsets

The FireSync Network cordset is a cable that contains two CAT5e cables within one shroud. One of these CAT5e cables is used to carry data between a sensor and a

network switch, and the other cable is used to send power, safety interlock, and synchronization signals to a sensor.

Shielded FireSync cordsets and shielded FireSync cable are optionally provided by LMI Technologies by customer request.



4.1.7 Other Cabling

Ethernet

Shielded CAT5e Gigabit Ethernet cable is used to connect a Station to a client PC. This cable will connect to the Station OUT.

Power

The 48VDC power supply must be connected to the master. Section 5.6.4 contains information about the power cable and connector.

Encoder

The user must provide a suitable encoder. The requirements are:

-
- Differential quadrature output (maximum 18 V)
 - +5VDC power supply input

The encoder interface on the Master provides the following:

- X4 quadrature decoding
- Maximum 300kHz count rate
- +5VDC to power the encoder

The user should choose an encoder with the appropriate number of pulses per revolution to match the transport mechanism and speed.

4.1.8 System Calibration Target

System calibration can be used to identify the location and orientation of each sensor with respect to a calibration target positioned in the measurement range of the sensor(s). After successful system calibration ranges from the sensor(s) are transformed to a new, common coordinate system.

The dimensions of the target can be configured manually, which allows for optimal flexibility in choosing a target. There are, however, properties that affect the chance on successful calibration. Here are some guidelines for choosing the right target shape, size, and positioning:

- Take a large (400mm X 400mm X ...mm), bar shaped object
- Make sure the sensors clearly see an edge vertex, ideally a right angle. Seeing the letter “V” when not calibrated, is ideal.
- Make sure as many points as possible are visible along each side of the vertex
- Avoid having objects in the FOV other than the calibration target

4.1.9 Sensors


Within a single chroma+scan sensor system various models can be used. Configurations in which sensors are mounted opposing each other are allowed. When working with more than one sensor the following restriction applies:

Laser lines may only intersect if the intersecting lines are from sensors in different groups. The maximum number of groups is two.

It is possible to use different configurations of sensors within each of the two groups, and no symmetry or alignment between groups is required.

4.2 Connections

The following illustration demonstrates how to connect the various components.



4.2.1 Power to Master 1200/2400

The 48 VDC power supply is wired to the Phoenix connectors on the Master. This powers the Master and is distributed to all the connected sensors in the system.

4.2.2 Master 1200/2400 to Sensors

Each sensor in the system is connected to the Master in order to receive power and synchronization signals. This connection is made using the FireSync Network Cordset.

The single connection at the sensor end is through the circular connector on the sensor. The connection at the Master end is from the black jacketed RJ45 cable. The yellow jacketed RJ45 cable end is connected to the Network Switch. Do not connect the yellow jacketed connector to a port on the master!

4.2.3 Safety Interlock on Master 1200/2400

The Safety Interlock signal allows the user to turn on and off all light sources in the sensors without disrupting power to the system. The laser safety control signal must be provided at the Master for the sensors to properly function.

To enable the laser safety control signal, apply between +12V and +48V across the laser safety +/- connection.

4.2.4 Sensors, Master 1200/2400 and Station to Gigabit Switch

The Gigabit switch connects all the sensor data lines with the Master and the Station.

Each sensor in the system connects to the Gigabit Switch with the yellow jacketed RJ45 cable end of the sensor Network Cordset.

The Master 1200/2400 connects to the Gigabit Switch via the “Link” port on the Master.

The Station connects via its “IN” port to the Network Switch.

4.2.5 Client computer

The Client computer is connected to the Station’s “OUT” Gigabit Ethernet adapter.

5 Specifications

5.1 Models

chroma+scan 24x0 sensors are available in three current models:

chroma+scan 2420: 4 Line Profiles, 12" Spacing, 120Hz, 4' Footprint

chroma+scan 2440: 4 Line Profiles, 6" Spacing, 120Hz, 2' Footprint

chroma+scan 2460: 8 Line Profiles, 6" Spacing, 120Hz, 4' Footprint

These models all provide the same profile scan zones with a choice of 6" or 12" profile spacing available in 2' or 4' sensor footprints.

5.2 Performance


Range Accuracy	chroma+scan 2420	±2.54 mm	±0.100 in
	chroma+scan 2440	±3.175 mm	±0.125 in
	chroma+scan 2460	±2.54 mm	±0.100 in
Profile Resolution	chroma+scan 2420	2.0 mm	0.079 in
	chroma+scan 2440	2.0 mm	0.079 in
	chroma+scan 2460	2.0 mm	0.079 in
Scan Resolution @ 2.3m/s (450 fpm)		19.05 mm	0.750 in

5.3 Environment

Operating Temperature	0 - 50°C	32 - 122°F
Input Power	+48VDC	
Housing	IP67, Powder Coated Aluminum	

5.4 Coordinate Definitions

Throughout this document and software interface, displacements are represented in x-, y- and/or z-coordinates. The coordinates are defined as follows:



Note: The direction of the X-axis can be changed on sensor by sensor basis. This is controlled by the “Orientation” field in the configuration file. Please refer to section 6.4.3.

5.5 Cleaning

The windows on a sensor must be kept clean and free of debris at all time. If the windows become dirty, clean them with an *ammonia-based* cleaner only.

5.6 Master 2400

5.6.1 Mechanical Information

Link, UP, DOWN, Sensor ports	RJ45
------------------------------	------

Power & Safety connector	Phoenix Contact MC 1,5/ 6-STF-3,5
Encoder connector	Phoenix Contact MC 1,5/ 8-STF-3,5
Input & Output connector	Phoenix Contact MC 1,5/ 12-STF-3,5
Ext. Sync. connector	Phoenix Contact MC 1,5/ 4-STF-3,5

5.6.2 Electrical Information

Power Supply voltage	+48 VDC
Power Supply current (Max.)	10A
Encoder signal voltage range	+0.475 VDC to +18 VDC
Digital Input voltage range	Logical LOW: 0VDC to +0.1 VDC Logical HI: +3.4 VDC to +5 VDC



The +48VDC power supply must be isolated from AC ground. This means that AC ground and DC ground are not connected.



If the user wishes to connect a higher voltage signal to the Digital Inputs, an external current limiting resistor must be used. The input already has an internal 330Ω resistor. Add an external resistor of the appropriate value such that the current to this input is **less than 15mA**.

5.6.3 LED Indicators

Indicator LED	Description
Link Green LED	Blinking: Ethernet traffic detected
Link Yellow LED	On: Connected Off: Not connected
UP Green LED	Reserved for future use
UP Yellow LED	Reserved for future use
DOWN Green LED	Reserved for future use
DOWN Yellow LED	Reserved for future use

Power	Device is powered on
Safety	Indicates the status of the Safety Interlock circuitry. The “On” state indicates that all sensor light sources are active
Encoder A	Encoder alarm: The encoder alarm is turned on when one of the encoder’s differential voltage signals (A, B or Z) fall below 0.475 volts
Encoder F	On continuously: Forward motion with no indexing is detected Blinking: Forward motion with indexing is detected
Encoder R	On continuously: Reverse motion with no indexing is detected Blinking: Reverse motion with indexing is detected
In 1	Digital input port 1 active
In 2	Digital input port 2 active
In 3	Digital input port 3 active
In 4	Digital input port 4 active
Out 1	Digital output port 1 active
Out 2	Digital output port 2 active
Sensor Port Green LED	On: Power over Ethernet device detected and powered Blinking: Error
Sensor Port Yellow LED	Unused


5.6.4 Terminal plugs

The Master uses four Phoenix Contact (MC 1.5/ series) terminal plugs:

- Power and Safety interface
- Encoder interface
- Digital I/O interface
- External Sync interface

Power and Safety (6-pin connector)

Pin	Signal
-----	--------




1	+48VDC
2	+48VDC
3	GND(48V)
4	GND(48V)
5	Safety Control +
6	Safety Control -



The +48VDC power supply must be isolated from AC ground. This means that AC ground and DC ground are not connected.


Encoder (8-pin connector)



Pin	Signal
1	A+
2	A -
3	B+
4	B -
5	Z+
6	Z -
7	GND
8	+5VDC

Digital I/O (12-pin connector)

Pin	Signal
1	Input 1
2	Input 1 GND
3	Input 2
4	Input 2 GND
5	Input 3
6	Input 3 GND



7	Input 4
8	Input 4 GND
9	Output 1
10	Output 1 GND
11	Output 2
12	Output 2 GND



This connector does not need to be wired up for proper system operation

External Sync (4-pin connector)

The features of this connector are not currently supported.

5.7 Cordsets


5.7.1 Network Cordset


- Maximum length 50m (164')
- RJ45 connectors (Master end)
- Binder 423-series 14-pin connector (sensor end, female)
- FireSync Dual CAT5e cable


5.7.2 Ethernet Cable

- Maximum length 100m (328')
- Solid-Core UTP cable
- RJ45 connectors
- CAT5e cable


5.8.1 chroma+scan 2420









5.8.3 chroma+scan 2460





5.8.4 Master 2400

Dimensions are in millimeters (mm)



6 Software

6.1 Components

The following table lists the provided software files. All files can be downloaded from the LMI Technologies support website.

Name	Description
14394-x.x.x.x_SOFTWARE_FireSync_Station.exe	Station installer. This installer provides FireSync Station (kStation.exe)
14379-x.x.x.x_CLIENT_chroma+scan_24x0.exe	Client installer. This installer provides FireSync Client (kClient.exe) and C-language source code to communicate with the Station.
14380-x.x.x.x_UPGRADE_chroma+scan_cs24x0.dat	Upgrade package. This file can be used to upgrade the chroma+scan 24x0 system.

The software interface to the Station, referred to as “the FireSync Host Protocol”, is OS independent. However, the Station and Client installers require Microsoft Windows XP or Windows 7.

6.2 Operation Modes

The system can operate in different operation modes, each of which has a specialized purpose. The following table defines the chroma+scan 24x0 modes.

Name	Description
Video	This operation mode will send out images from one sensor in the system at a low, fixed frame rate. Video mode is used for diagnostics.
Free	Free mode transmits ranges from the system on a time based interval.
Calibration	Calibration mode performs a system calibration. It creates a uniform world coordinate system for all sensors in the system. The output messages

	contain a status flag to indicate the progress of the calibration.
--	--

As the system runs, data will be transmitted to the Client computer in the *FireSync Result Format*. The general format is described in the *Host Protocol Reference Manual* on page 28. Refer to 6.4.4, 6.4.5 and 6.3.6 for detailed information on how the data can be interpreted in the various operation modes.

6.3 FireSync Client


FireSync Client (kClient.exe) is a software application that can be used to set up, demonstrate or diagnose the operation of the chroma+scan 24x0 system. The following sections describe the most common activities performed with the FireSync Client application.

6.3.1 Installation

The FireSync Client application is available for Microsoft Windows XP and Windows 7. Obtain the software from LMI Technologies and install it on a suitable Client Computer.

6.3.2 Connection


After starting FireSync Client, use the lightning (left-most) icon in the toolbar to display the “Connect...” dialog. To connect to the, enter the public IP address of the machine running FireSync Station and then click “OK”.




6.3.3 Navigation

Upon successful connection kClient provides access to configuration parameters and operation modes.

The system topology pane is shown in the top left corner of the application. This pane allows selecting the system, a group or individual sensors. Right-clicking an entry in the topology pane brings up a pop-up menu. Assign a serial number to each of the entries in the device tree, as shown below. A sensor can also be temporarily disabled through this menu.




Clicking on a node opens a number of tabs relating to the selected node. These tabs are shown in the center part of the application.



Selecting the “System” entry in the device tree will bring up (configuration) tabs “*Setup*” and “*Calibration Target*” as well as the “*Free*” and “*Calibration*” (operation) tabs.

In the “Setup” tab, the number of groups and sensors per group can be defined. This will affect the topology pane. General settings can also be changed from the “Setup” tab.




Where tab names match with the operation modes defined in ..., the Run button (black triangle) in the toolbox becomes active.



After clicking on this button FireSync Client starts the system in the selected mode and visualizes the data in the leftmost part of the application window. Press the Stop button (black square) to finish.


6.3.4 Video Mode

Select a sensor in the device tree, and then select the “*Video*” tab. Press the Run button (black triangle) in the toolbar, and observe the incoming video images from each camera. If there is an object within the field of view of the sensors, you will see laser images appear in the display.



6.3.5 Free Mode

Select the server in the device tree, and then select the “Free” tab. Press the Run button (black triangle) in the toolbar, and observe the incoming profile data. You can right-click on the graphic display for options. Note that there is also a “Free” tab for each sensor in the device list. These sensor-level “Free” tabs can be used to isolate the data from a single device.



6.3.6 Calibration Mode

Before a system calibration can be performed, a target needs to be defined. Select the server in the device tree, and then select the Calibration Target tab. The default values define a target square target at X, Z = (0, 0) with a 300mm size.

The screenshot shows the 'Calibration Target' tab of a software interface. It contains a table for 'Calibration Target Definition' and two input fields for 'Sensor Calibration'.

Vertex	X[mm]	Z [mm]
0 :	0	0
1 :	0	300
2 :	300	300
3 :	300	0

Below the table, the 'Sensor Calibration' section has two input fields: 'Vertex X' with a value of 0, and 'Vertex Z' with a value of 0.

Warning! Always define vertices in clockwise order.


After that for each sensor a number of settings need to be specified. “Vertex View” indexes an entry in the calibration target definition. “Invert Orientation” can be used to mirror the X-axis of the sensor. The “Clip” field and belonging “Minimum X” and “Maximum X” fields allow masking out regions of the FOV.

The screenshot shows the 'Sensor' tab of the software interface. It contains a section for 'Sensor Properties' with several configuration options.


Sensor Properties

- Vertex View: A dropdown menu showing 'Vertex 1'.
- Invert Orientation: A checked checkbox.
- Clip: A checked checkbox.
- Minimum X: An input field with the value '-300' and a unit 'mm'.
- Maximum X: An input field with the value '300' and a unit 'mm'.

Press the Run button (black triangle) in the toolbar, and observe the calibration status for each sensor. When “*Complete*” is indicated Stop button to finish system calibration.



After system calibration the ranges from the sensor will be transformed according to the calibration target definition and the associated vertex view for each sensor.



6.4 Software Interface

6.4.1 The FireSync Host Protocol

The FireSync Host Protocol enables communication between any FireSync based sensor system and any Operating System that supports TCP/IP. Besides the general FireSync Host Protocol rules some specific rules apply for the chroma+scan 24x0 system.

The next sections describe the aspects of communication that are specialized for the chroma+scan 24x0 system. Please see the *FireSync Host Protocol Reference Manual* for a detailed description of the protocol and use this manual for the specialized aspects.

6.4.2 Zen Api and example source code

The chroma+scan 24x0 installer ships with a C-language source code that implements the FireSync Host Protocol and all the supported modes.

The source code is split up into two projects:

- the Zen API (zApi)
- example code that uses the Zen API

The Zen API is LMI's common library for that provides basic classes for things like: networking, threading and XML parsing. The example code shows how to use the Zen API in a console based application and provides basic functionality to operate the chroma+scan 24x0 system.

After installing the chroma+scan 24x0 client package, various files and folders are found inside the installation folder. The following table provides an overview of these entities.

Name	Description
Bin	Place holder for executables
include	Zen Api include files to compile your application against
Lib	Place holder for import library to link your application against
example	Example source for chroma+scan 24x0
zApi	Zen Api source files

The top-level directory contains documentation for the Zen API.

6.4.3 System Settings

The chroma+scan 24x0 system is configured by an XML file inside the storage of the Station. This file is called “*Settings.xml*”. Use the “*Write File*” host protocol command to write transfer settings into the Station.

The following example illustrates the format of the “*Settings.xml*” file:

```
<?xml version="1.0" ?>
<SensorGroup>
  <Exposure>0</Exposure>
  <VideoMode>
    <Sensor>1234</Sensor>
  </VideoMode>
  <FreeMode>
    <OutputBatchCount>1</OutputBatchCount>
  </FreeMode>
  <CalibrationTarget>
    <Vertex>
      <X>0</X>
      <Z>0</Z>
    </Vertex>
    <Vertex>
      <X>0</X>
      <Z>300</Z>
    </Vertex>
    <Vertex>
      <X>300</X>
      <Z>300</Z>
    </Vertex>
    <Vertex>
      <X>300</X>
      <Z>0</Z>
    </Vertex>
  </CalibrationTarget>
  <Members>
    <Group>
      <Name>Group 1</Name>
      <Members>
        <Sensor>
          <Name>Sensor 0</Name>
          <SerialNumber>1234</SerialNumber>
          <Enabled>0</Enabled>
          <VertexView>0</VertexView>
          <Orientation>0</Orientation>
          <Clip>0</Clip>
          <XMin>0</XMin>
          <XMax>0</XMax>
        </Sensor>
        <Sensor>
```

```

        <Name>Sensor 1</Name>
        <SerialNumber>4294967295</SerialNumber>
        <Enabled>0</Enabled>
        <VertexView>0</VertexView>
        <Orientation>0</Orientation>
        <Clip>0</Clip>
        <XMin>0</XMin>
        <XMax>0</XMax>
    </Sensor>
</Members>
</Group>
</Members>
</SensorGroup>

```

The example above specifies the settings for a system with four sensors. System-level settings include the following entries:

Setting			Description
Exposure			Specifies whether high or low exposure is used. This set the sensor speed to either, 120Hz, 90Hz or 60Hz
Video			Contain options that are applicable only in Video mode
	Sensor		Serial Number of the sensor from which to show video data
Free			Contain options that are applicable only in Free mode
	OutputBatchCount		The number of profiles batched together in a single message. NOTE! Currently unsupported.
CalibrationTarget			Defines the calibration target geometry. Needs at least three vertex sections.
	Vertex		
		X	Translation coefficient X in millimeters
		Z	Translation coefficient Z in millimeters
		T	Rotation coefficient in radians
Members			Contains one or two groups
	Group		
		Name	Must be unique
		Members	Contains variable number of sensors

			Sensor	
			Name	Must be unique within a group
			SerialNumber	Indexes one vertex in the CalibrationTarget section
			Enabled	Enables / Disabled the sensor
			VertexView	Indexes one vertex in the CalibrationTarget section
			Orientation	Invert (mirror) X-axis for this sensor ... 0: Default orientation (as in section 5.4) 1: Inverted orientation
			Clip	Enables X clipping
			XMin	Minimum X
			XMax	Maximum X

6.4.4 Video Mode Result Format

Video mode transmits video images at a low, fixed frame rate. Video mode messages have one data block and Message Identifier (ID) 0. The *Get Mode* and *Set Mode* Host Protocol commands use the string “*Video*” for this mode.

Video Message Attributes

Field	Type	Description
deviceId	64s	Sensor serial number
viewIndex	64s	Camera index

Video Message Descriptors [0]

Field	Value	Description
Length0	height	Image height
Length1	width	Image width
Length2	0	N/A

Video Message Data [0]

Field	Type	Description
pixels[height][width]	8u	Image pixels

6.4.5 Free Mode Result Format

In Free mode, range coordinates are transmitted as (X, Z) pairs. Free mode has at least two data blocks. The first (odd) data block contains information about the sequence index, capture time, capture position and digital input states. The second (even) data block contains the actual (X, Z) pairs for each line. To reduce the network overhead Free Mode supports output batching. Output batching affects the number of data blocks. Since even and odd data blocks belong together, the number of data blocks will always be a multiple of two. Similarly the batch count can be determined by dividing the number of data blocks by two.

Free mode messages have ID 1 and use the string “Free” in the *Get Mode* and *Set Mode* Host Protocol commands.

Free Message Attributes

Field	Type	Description
deviceId	64s	Sensor serial number
xResolution	64s	Unit of X values (microns)
yResolution	64s	Spacing between laser lines (microns)
zResolution	64s	Unit of Z values (microns)
nullRange	64s	Value representing an invalid profile point

Free Message Descriptors [2 * batchcount]

Field	Value	Description
Length0	4	Number of entries in: Free Message Data[2 * batchcount]
Length1	0	N/A
Length2	0	N/A

Free Message Descriptors [2 * batchcount + 1]

Field	Value	Description
Length0	lines	Number of lines.
Length1	width	Number of ranges per profile. The number is determined by characteristics of the sensor during manufacturing.
Length2	2	Number of channels is two: X and Z

Free Message Data [2 * batchcount]

Field	Type	Description
frameIndex	64s	Sequence index within a view
Timestamp	64s	Capture time (microseconds)
Position	64s	Capture position (encoder count)
Input State	64s	Digital inputs

Free Message Data [2 * batchcount + 1]

Field	Type	Description
ranges[lines][width][2]	16s	Ranges: X and Z

6.4.6 Calibration Mode Result Format

Calibration mode performs a system calibration. It creates a uniform world coordinate system for all sensors in the system. The output messages contain a status flag to indicate the progress of the calibration for each sensor in the system and each line. Calibration mode messages have a variable amount of data blocks, depending on the number of sensors. The Message ID is 4.

The *Get Mode* and *Set Mode* Host Protocol commands use the string “*Calibration*” for this mode.

Free Message Attributes

Field	Type	Description
deviceId0	64s	Sensor serial number for 0 th sensor
deviceId1	64s	Sensor serial number for 1 ^h sensor
...		

Calibration Message Descriptors [sensorcount]

Field	Value	Description
Length0	lines	Number of lines
Length1	0	N/A
Length2	0	N/A

Calibration Message Data [sensorcount]

Field	Type	Description
Statistics0	64s	Status of calibration for 0 th line
Statistics1	64s	Status of calibration for 1 th line
...		

Status codes

Status	Description
1	Complete
0	Busy
-1	Error Code -1
-2	Error Code -2
...	...

7 Warranty

7.1 Warranty policies

The sensor is warranted for a predetermined number of years from the date of purchase from LMI Technologies Inc. This warranty period is defined by your business agreement in place with LMI Technologies. For exact warranty periods by product, please contact your Business Development Manager. Products that are found to be non-conforming during their warranty period are to be returned to LMI Technologies Inc. The sensor must be properly handled, installed and maintained, as described in Section 2: Proper Handling and Precautions. LMI will void the warranty of the sensor if the sensor has been improperly installed or mishandled.

The shipper is responsible for covering all duties and freight for returning the sensor to LMI. It is at LMI's discretion to repair or replace sensors that are returned for warranty work. LMI Technologies Inc. warranty covers parts, labor and the return shipping charges. If the warranty stickers on the sensors are removed or appear to be tampered with, LMI will void the warranty of the sensor.

7.2 Return policy

Before returning the product for repair (warranty or non-warranty) a Return Material Authorization (RMA) number must be obtained from LMI. Please call LMI to obtain this RMA number. Carefully package the sensor in its original shipping materials (or equivalent) and ship the sensor prepaid to your designated LMI location. Please insure that the RMA number is clearly written on the outside of the package. With the sensors, include the address you wish this shipment returned to, the name, email and telephone number of a technical contact should we need to discuss this repair, and details of the nature of the malfunction. For non-warranty repairs, a purchase order for the repair charges must accompany the returning sensor. LMI Technologies Inc. is not responsible for damages to a sensor that is the result of improper packaging or damage during transit by the courier.

8 Getting Help

If you wish further help on the component or product, contact your distributor or LMI directly. Visit our website at www.lmi3D.com for the agent nearest you.

For more information on Safety and Laser classifications, contact:

U.S. Food and Drug Administration
Center for Devices and Radiological Health
Document Mail Center – WO66-G609
10903 New Hampshire Avenue
Silver Spring, MD 20993-0002